



- ① "P" SERIES STAINLESS STEEL PEDESTAL ENCLOSURE. INSTALL ENCLOSURE PER MFG. INSTRUCTIONS. BASESTATION 3200 OR BASESTATION 1000 CONTROLLERS MAY IN BE INSTALLED IN THIS PEDESTAL.
- ② CONCRETE PAD 6" MIN. THICKNESS
- ③ FINISHED GRADE
- ④ COMPACTED SUB-GRADE
- ⑤ SCHEDULE 40 PVC CONDUIT SIZE PER CODE, FITTINGS AND SWEEP ELL FOR POWER SUPPLY
- ⑥ POWER SUPPLY
- ⑦ SCHEDULE 40 PVC CONDUIT, FITTINGS AND SWEEP ELL FOR IRRIGATION WIRES. SIZE PER LOCAL CODE
- ⑧ IRRIGATION ZONE WIRES TO FIELD
- ⑨ SURFACE TREATMENT OR LAWN

- NOTES:
- 1. BASESTATION CONTROLLERS ARE EQUIPPED WITH BUILT-IN ETHERNET PORT.
 - 2. ADDITIONAL CONDUITS MAY BE REQUIRED FOR GROUNDING AND COMMUNICATION CABLES.
 - 3. PROPER GROUNDING IS REQUIRED TO ACHIEVE GROUND RESISTANCE OF 10 OHMS OR LESS.
 - 4. SEE MOUNTING TEMPLATE INSTRUCTIONS FOR PROPER PLACEMENT AND MOUNTING OF THE PEDESTAL TO THE CONCRETE.

"P" STAINLESS STEEL PEDESTAL

NTS